



Delaware County

Regional Sewer District

Director/Sanitary Engineer
Tiffany M. Maag, P.E.

September 18, 2023

Jacob Wentz
Kimley-Horn
7965 N High Street, Ste 200
Columbus, OH 43235

sent via email: jacob.wentz@kimley-horn.com

Re: **Request for Sewer Capacity**
Farneman Property
Parcels: 60021002026000

Dear Mr. Wentz:

The Delaware County Regional Sewer District (the "County") has considered your request for approval to discharge sanitary sewage into the Delaware County Sanitary Sewer System from the above referenced location, representing a maximum 140 Equivalent Residential Unit(s) (ERU).

Capacity is conditionally available to serve the proposed project. An existing 36" sanitary sewer is located to the north of the identified parcels. Extensions from the existing sanitary sewer will be necessary to provide service to the proposed lots. Ultimately, a 24" sanitary sewer extension will be necessary to the southern property line of this proposed development.

The current assessment of capacity availability is subject to periodic reevaluation by the County and shall not be valid after 18 months from the date of this letter.

If you have any questions, please feel free to contact me.

Sincerely,

A handwritten signature in black ink that reads "Kelly Thiel".

Kelly Thiel
Staff Engineer III
Delaware County Regional Sewer District

cc: Correspondence File

EXHIBIT E-4